2020 JUN -5 AM 8: 09

2019 CERTIFICATION

Consumer Confidence Report (CCR)

Mississippi State University

Public Water System Name PWS # 0530012

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR

mus requ	t be mailed or delivered to the customers, published in a newspuest. Make sure you follow the proper procedures when distributed a copy of the CCR and Certification to the MSDH. Please	paper of local circulation, or provided to the customers upon outing the CCR. You must email, fax (but not preferred) or
×	Customers were informed of availability of CCR by: (At	
	☐ Advertisement in local paper (Attac.	
	☐ On water bills (Attach copy of bill)	
	☐ Email message (Email the message	
	☐ ☑ Other News Release from MSU (w	www.msstate.edu)
	Date(s) customers were informed: 6 / 2 /2020	/ /2020 / /2020
1.1	CCR was distributed by U.S. Postal Service or other methods used	
	Date Mailed/Distributed://	
×	CCR was distributed by Email (Email MSDH a copy)	Date Emailed; 6 / 3 / 2020
		dents/publications-policies/ (Provide Direct URL)
	annual-water-report □ As an attachment	
	☐ As text within the body of the email	il message
	CCR was published in local newspaper. (Attach copy of	f published CCR or proof of publication)
	Name of Newspaper:	
	Date Published:/	
1	CCR was posted in public places. (Attach list of location	ons) Date Posted: / / 2020
X	CCR was posted on a publicly accessible internet site at	t the following address:
I her	ATIFICATION The property of the customers of the customer	of this public water system in the form and manner identified
and c	e and that I used distribution methods allowed by the SDWA. I ficorrect and is consistent with the water quality monitoring data provealth, Bureau of Public Water Supply	further certify that the information included in this CCR is true ovided to the PWS officials by the Mississippi State Department
	h off	
Nam	ne/Title (Board President Mayor, Owner, Admin. Contact, etc.)	Date
	Director of Procurement & Contracts ubmission options (Select	ct one method ONLY)
	Mail: (U.S. Postal Service)	Email: water.reports@msdh.ms.gov
	MSDH, Bureau of Public Water Supply P.O. Box 1700	Fax: (601) 576 - 7800

Jackson, MS 39215

**Not a preferred method due to poor clarity **

CCR Deadline to MSDH & Customers by July 1, 2020!

2019 Annual Drinking Water Quality Report Mississippi State University PWS#: MS 0530012 May 2020

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Gordo Formation Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Mississippi State University have received lower to moderate susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Dave Maharrey at 662.325.7205. We want our valued customers to be informed about their water utility. This report will be published on the Mississippi State University Website:http://www.msstate.edu/students/publications-policies/annual-water-report.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st, 2019. In cases where monitoring wasn't required in 2019, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

l/addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

				TEST RES	SULTS			
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure- ment	MCLG	MCL	Likely Source of Contamination
Radioactiv	e Conta	minants						
6. Radium 226 Radium 228	N	2019	.78 1.7	.6778 No Range	pCi/L	0	5	Erosion of natural deposits
Inorganic (Contami	inants						
8. Arsenic	N	2019	1.4	.5 – 1.4	ppb	n/a	10	Erosion of natural deposits; runof from orchards; runoff from glass and electronics production waste
10. Barium	N	2019	.0971	.03850971	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2019	.9	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits

14. Copper	N	2016/18	* 0	0	ppm			1.3	AL=	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2019	₄ 126	.113126	ppm			4		4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2016/18	* 1	0	ppb			0	AL=15		Corrosion of household plumbing systems, erosion of natural deposits
Sodium	N	2019	33000	25000 - 3300	0 PPB			0	0		Road Salt, Water Treatment Chemicals, Water Softeners and Sewage Effluents.
Disinfecti	on By-	Product	S	111							
Chlorine	N	2019	1	.54 – 1.3	mg/l		0	MDI	RL = 4 Water additive used to cont microbes		
Unregula	ted Co	ntamina	nts								
Bromide	N	2019	54.2	25.9 – 54.2	UG/L					Naturally-occurring element found in the earth's crust and at low concentrations in seawater, and in some surface and ground water; cobaltous chloride was formerly used in medicines and as a germicide	
Germanium	N	2019	.31	No Range	UG/L	0).3	M	available in combination with other		ments and minerals; a byproduct of zine processing; used in infrared optics, er-optic systems, electronics and solar
Manganese	N	2019	84.8	12.3 – 84.8	UG/L				available in combination with other elements and minerals; used in steel production, fertilizer, batteries and		ments and minerals; used in steel duction, fertilizer, batteries and works; drinking water and wastewater
HAA5	N	2019	1.52	No Range	UG/L						
HAA6BR	N	2019	1.75	No Range	UG/L						
HAA9	N	2019	2.85	No Range	UG/L						

^{*} Most recent sample. No sample required for 2019.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead. The Mississispipi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulations are warranted.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Mississippi State University works around the clock to provide top quality water to every tap. We ask that all our students help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Cockrell, Joan

From: massmail-return@its.msstate.edu on behalf of null-address < null-

address@msstate.edu>

Sent: Wednesday, June 03, 2020 6:30 AM

To: null-address

Subject: Mississippi State releases annual 'Drinking Water Quality Report'

Mississippi State is pleased to announce that the university's water system has met all of the requirements of the Mississippi State Department of Health.

The water quality report, also referred to as the Consumer Confidence Report, must be provided to customers annually. The annual testing is administered by MSDH.

The 2019 full report is available online at https://www.msstate.edu/students/publications-policies/annual-water-report/

Please direct any questions to MSU Facilities Management at 662-325-5830.

------Submission Data------

Contact: Dave Maharrey

Submitter confirms that this announcement meets the requirements of MSU Policy OP 60.123 regarding invitations to University events.

Recipients: Faculty, Staff, Undergraduate Students, Graduate Students, Deans, Directors and Department Heads,

Benefits Eligible Employees, Affiliates at Main Starkville Campus

Authorized-By: Vice President for Division of Finance